

附表八 型式試驗報告審查採用基準版本列表

| 設備名稱             | 標準名稱   | 適用標準               | 審查基準版本            |
|------------------|--|--------------------|-------------------|
| 1.避雷器            | Surge arresters - Part 1:<br>Non-linear resistor type gapped arresters for a.c. systems                        | IEC 60099-1        | 1999/12/22(ed3.1) |
| 1.避雷器            | Surge arresters - Part 4:<br>Metal-oxide surge arresters without gaps for a.c. systems                         | IEC 60099-4        | 2009/5/27(ed2.2)  |
| 1.避雷器            | IEEE Standard for Metal-Oxide Surge Arresters for AC Power Circuits (> 1 kV)                                   | IEEE Std C62.11    | 2005              |
| 2.電力及配電變壓器       | Power transformers - Part 1: General   | IEC 60076-1        | 2000/4/7(ed2.1)   |
| 2.電力及配電變壓器       | Power transformers - Part 10: Determination of sound levels  | IEC 60076-10       | 2001/5/22(ed1.0)  |
| 2.電力及配電變壓器       | Power transformers - Part 11: Dry-type transformers  | IEC 60076-11       | 2004/5/27(ed1.0)  |
| 2.電力及配電變壓器       | IEEE Standard for General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers    | IEEE Std C57.12.00 | 2006              |
| 2.電力及配電變壓器       | IEEE Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers                   | IEEE Std C57.12.90 | 2006              |
| 3.比壓器            | Instrument transformers - Part 2 : Inductive voltage transformers  | IEC 60044-2        | 2003/2/13(ed1.2)  |
| 3.比壓器            | Instrument transformers - Part 5 : Capacitor voltage transformers  | IEC 60044-5        | 2004/4/14(ed1.0)  |
| 3.比壓器            | Instrument transformers - Part 5: Additional requirements for capacitor voltage transformers                   | IEC 61869-5        | 2011/7/13(ed1.0)  |
| 3.比壓器            | IEEE Standard Requirements for Instrument Transformers   | IEEE Std C57.13    | 2008              |
| 4.比流器            | Instrument transformers - Part 1: Current transformers   | IEC 60044-1        | 2003/2/13(ed1.2)  |
| 4.比流器            | IEEE Standard Requirements for Instrument Transformers   | IEEE Std C57.13    | 2008              |
| 5.熔絲             | High-voltage fuses - Part 1: Current-limiting fuses  | IEC 60282-1        | 2005/11/21(ed6.0) |
| 5.熔絲             | High-voltage fuses - Part 2: Expulsion fuses   | IEC 60282-2        | 2008/4/29(ed3.0)  |
| 6.氣體絕緣開關設備 (GIS) | High-voltage switchgear and controlgear - Part 203: Gas-insulated metal-enclosed switchgear for rated voltages | IEC 62271-203      | 2003/11/6(ed1.0)  |

|                       |  |               |                   |
|-----------------------|--|---------------|-------------------|
|                       | above 52 kV  |               |                   |
| 7.斷路器                 | High-voltage switchgear and controlgear - Part 100: Alternating current circuit-breakers   | IEC 62271-100 | 2003/5/23(ed1.1)  |
| 7.斷路器                 | High-voltage switchgear and controlgear - Part 1: Common specifications  | IEC 62271-1   | 2007/10/24(ed1.0) |
| 8.高壓配電盤(亦適用於氣體絕緣開關設備) | High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV | IEC 62271-200 | 2003/11/6(ed1.0)  |

說明：型式試驗報告應符合審查基準版本或更新版本。倘係依審查基準版本以前之版本者，應就與審查基準版本差異處及試驗不足處提出補充報告或說明。